

Brendale Office
Job: BL 15-029
Ref: 10132
Author: M. Morrison

11th November 2015

Pensar Civil Pty Ltd
8 Hockings St
South Brisbane Qld 4101

ATTENTION: MR NICK SOMERVILLE
Email: nicks@pensar.com.au

Dear Sir,

**RE: LEVEL ONE SUPERVISION AND TESTING
ASTON GROVE STAGE 1A AND 1B
DARRIEN STREET BRIDGEMAN DOWNS.**

Level One Supervision, field testing and associated laboratory testing was carried out on earthworks filling operations constructed by Pensar Civil to form residential building platforms and road subgrades at Aston Grove Stage 1A and 1B at the above site.

Our representative observed all of the relevant earthworks operations including the stripped ground surface, proof roll testing, observations of the placement and compaction methodologies and compaction testing in accordance with the require Standard (AS3798). The required compaction specification of 95% Standard was achieved at each test location.


We confirm that Level One Supervision and associated testing has been carried out on the fill materials that support residential building platforms and road subgrades at this site. The fill constructed at this site is controlled as defined in AS2870 and was observed to be placed and compacted in accordance with AS3798.

This statement excludes any topsoil, slope stability, trench backfill, site classification or any other subsequent work after 10th August 2015.

JFP Drawing Number EW01, EW02, indicate where fill was to be placed and compacted at The Site. Fill areas as shown on the Earthworks Plans are considered to be a reasonable estimation of the fill extremities and depths.

Should you require additional information regarding the above, please do not hesitate to contact this office.

Yours faithfully,



MICHAEL MORRISON
For and on Behalf of
MORRISON GEOTECHNIC